

**Leyden Township**

**RE: IL0315880 Consumer Confidence Annual Water**

**Report January 1, 2024 to December 31, 2024**

This publication conforms to the new federal regulation under the S.D. W.A. that requires water utilities to provide detailed water quality to each of their customers annually. Leyden Township must provide you with this information.

This report is intended to provide you with important information about your drinking water and efforts made by Leyden Township Water Department to provide safe drinking water to all residents.

If you have any questions relating to your water supply, and this report, please contact Mr. Marcin Mitek, Certified Water Operator for Leyden Township at 847-455-8616.

Have a friend or relative translate this report to non-speaking/reading resident.

This Report will try to answer most common questions about your drinking water. Leyden Township receives its water originally from the City of Chicago via Lake Michigan. The water is then purchased through the Village of Melrose Park water supply system and the Franklin Park water system.

Lake Michigan is the surface water supply used to provide drinking water for Chicago and 123 suburban communities. The Environmental Protection Agency (EPA) has found that the quality of Lake Michigan has improved dramatically over the past 24 years. Lake Michigan, by volume, is the second largest Great Lake and the only one located totally within the United States. It serves as a source of drinking water, as a place for swimming and fishing, and as a scenic wonderland. Sources of drinking water used for both tap water and bottled water can pick up contaminants as water travels over the surface of the land or through the ground. The drinking water source is vulnerable to industrial waste and runoff from surrounding lands. Potential sources of pollution such as pesticides, herbicides, radioactive materials, and organic and inorganic petroleum and gas production by-products can impact the source water. We do not have indications of the presence of these contaminants at this time, mainly because of restrictions, which prohibit industrial effluents from entering Lake Michigan; Sewage treatment plant effluents are not discharged into the lake, thereby reducing the threat of microbial contamination. All 63 miles of shoreline within Illinois are now considered to be in good condition. The Illinois EPA Office of Groundwater will be doing a source water assessment within the next three years. When completed, all sources of Pollutants into Lake Michigan will be identified and there will be information regarding the source water's susceptibility to contaminants based on the findings of the assessment. Since the quality of the raw water source is good, conventional treatment methods of disinfection, coagulation and sedimentation, and sand filtration are adequate for producing water that is free of harmful contaminants.

The City of Chicago Water Department provides the water treatment necessary to safeguard the water delivered through Melrose Park and then on to Leyden Township. Water is taken from Lake Michigan at several water inlets located just off shore. Chlorine is then injected into the water for disinfection. The water is processed through settling and filtration where the water is filtered to remove any sedimentation that exists in the water. After any remaining particles are removed the water is then re-chlorinated as a precaution to eliminate any microorganisms still remaining. The City of Chicago Water Department monitors and proceeds with voluntary testing for many contaminants which are regulated but no current standards currently exist.

**Cryptosporidium:** a microscopic organism that can cause illness similar to that of gastrointestinal symptoms. Analyses have been conducted monthly. Cryptosporidium has not been detected in any sample testing. Treatment processes have been optimized to ensure that if there are cryptosporidium cysts in the source water they will be removed during the treatment process. By maintaining a low Turbidity (cloudiness from soil runoff), through proper filtration and disinfectants, the threat of cryptosporidium organisms in the drinking water system is dramatically reduced.

**Asbestos:** samples are examined for asbestos fibers in the source water and finished water on a routine basis. The EPA has determined that asbestos fibers in high levels for long periods of time may cause lung cancer. Fibers in high levels have not been found.

**Sodium:** there is not a state or federal acceptable level for sodium amounts in water. The City of Chicago is required to provide information to consumers and health officials that are concerned about sodium intake due to dietary precautions.

The water is now ready to be distributed to adjoining towns. The city of Chicago carefully monitors the chlorine amounts so as not to compromise taste and odor. Fluoride is also added to fight the battle of tooth decay.

Leyden Township Water Department also monitors the levels of contaminants exiting in the water as it enters our distribution system, adding chlorine when tests results show abnormal levels of contaminants. The Township works adamantly to ensure the delivery of safe and tasteful drinking water to all its residents.

#### **SPECIAL HEALTH INFORMATION**

##### **FROM THE UNITED STATES ENVIRONMENTAL PROTECTION AGENCY**

Drinking water, including bottled **water**, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

##### **Contaminants that might be present in source water include:**

**Microbial Contaminants:** such as viruses and bacteria, this may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

**Inorganic Contaminants:** such as salts and metals, which can be naturally occurring or result from urban storm water runoff, domestic wastewater discharges, oil and gas production, mining or farming.

**Pesticides and Herbicides:** This may come from a variety of sources such as agriculture, urban storm water runoff and residential uses.

**Organic Chemical Contaminants:** including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production and can also come from gas stations, urban storm water runoff and septic systems.

**Radioactive Contaminants:** which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure the tap water is safe to drink, EPA prescribes regulations which limit the number of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791.

The water, originating from the City of Chicago, is purchased through the Village of Melrose Park's water system and stored in the Township's 1-million-gallon water tank, located on 25<sup>th</sup> Ave. It is then pumped throughout the Township's pumping station, located adjacent from the water tank, throughout the township on demand.

The attached tables show the Water Quality Data for the sources of water from which Leyden Township receives its water for distribution, via City of Chicago and Village of Melrose Park. These reports showing any and all detected contaminants results monitored for the 2023 calendar year can be found on the **IEPA** website.

#### **Water Conservation Tips**

Water conservation measures are an important first step in protecting our water supply. Such measures not only save the supply of our source water, but can also save you money by reducing your water and sewer bills. Here are a few suggestions.

Fix leaking faucets, pipes, toilets, etc.

Replace old fixtures; install water-saving devices in faucets, toilets and appliances.

Wash only full loads of laundry.

Do not use the toilet for trash disposal.

Take shorter showers.

Do not let water run while shaving or brushing teeth.

Soak dishes before washing.

Run the dishwasher only when full. You can conserve outdoors as well:

Water the lawn and garden in the early morning or evening.

Use mulch around plants and shrubs.

Repair leaks in faucets and hoses.

Use water-saving nozzles.

Use water from a bucket to wash your car, and save the hose for rinsing.

#### **Unit of Measurement - Definition**

*Ppt. Parts per trillion, or nanograms per liter*

*ppm \_ Parts per million, or milligrams per liter*

*ppb \_Parts per billion, or micrograms per liter*

*Pei/l. Pico curies per liter, used to measure radioactivity*

Consumer Confidence Report

Annual Drinking Water Quality Report

LEYDEN TWSP WATER DISTRICT

IL0315880

Annual Water Quality Report for the period of January 1 to December 31, 2024

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by LEYDEN TWSP WATER DISTRICT is Purchased Surface Water

For more information regarding this report contact:

Name MARCIN MITEK

Phone 847-254-7564

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water	
<p>The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.</p>	<p>Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.</p>
<p>Contaminants that may be present in source water include:</p> <ul style="list-style-type: none"> <li>- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.</li> <li>- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.</li> <li>- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.</li> <li>- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.</li> <li>- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.</li> </ul>	<p>In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.</p> <p>Some people may be more vulnerable to contaminants in drinking water than the general population.</p> <p>Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).</p> <p>Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The drinking water supplier is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standard Institute accredited certifier.</p>

to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested, contact MARCIN MITEK at 847-254-7564. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Source Water Information

Source Water Name	Type of Water	Report Status	Location
CC 01-HSP DISCHARGE LINE	FF IL0311860 TP02: LAKE	SW	

## Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at ~~312-254-7564~~. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: CHICAGO The Illinois EPA considers all surface water sources of community water supply to be susceptible to potential pollution problems. The very nature of surface water allows contaminants to migrate into the intake with no protection only dilution. This is the reason for mandatory treatment for all surface water supplies in Illinois. Chicago's offshore intakes are located at a distance that shoreline impacts are not usually considered a factor on water quality. At certain times of the year, however, the potential for contamination exists due to wet-weather flows and river reversals. In addition, the placement of the crib structures may serve to attract waterfowl, gulls and terns that frequent the Great Lakes area, thereby concentrating fecal deposits at the intake and thus compromising the source water quality. Conversely, the shore intakes are highly susceptible to storm water runoff, marinas and shoreline point sources due to the influx of groundwater to the lake.

**2024 Regulated Contaminants Detected**

**Lead and Copper**

Definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Copper Range: ND to 399 ug/L  
 Lead Range: ND to 9.37 ug/L

To obtain a copy of the system's lead tap sampling data: VISIT WWW.LEYDEN TOWNSHIP.COM

CIRCLE ONE: Our Community Water Supply has/has not developed a service line material inventory.

To obtain a copy of the system's service line inventory: VISIT WWW.LEYDEN TOWNSHIP.COM

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/13/2023	1.3	1.3	0.129	0	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits.
Lead	09/13/2023	0	15	6.08	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

**Water Quality Test Results**

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Water Quality Test Results**

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na: not applicable.

mrem: millirems per year (a measure of radiation absorbed by the body)

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

**Regulated Contaminants**

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2024	1	0.64 - 1.15	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2024	16	9.4 - 26.7	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2024	34	17.8 - 57.3	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

# 2024 Water Quality Data

DATA TABULATED BY CHICAGO DEPARTMENT OF WATER MANAGEMENT  
0316000 CHICAGO

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Highest Level Detected:** This column represents the highest single sample reading of a contaminant of all the samples collected in 2024.

**Range of Detections:** This column represents a range of individual sample results, from lowest to highest that were collected during the CCR calendar year.

**Date of Sample:** If a date appears in this column, the Illinois EPA requires monitoring for this contaminant less than once per year because the concentrations do not frequently change. If no date appears in the column, monitoring for this contaminant was conducted during the Consumer Confidence Report calendar year.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**N/A:** Not applicable

## DETECTED CONTAMINANTS

Contaminant (unit of measurement) <i>Typical source of Contaminant</i>	MCLG	MCL	Highest Level Detected	Range of Detections	Violation	Date of Sample
<b>Turbidity Data</b>						
Turbidity (NTU/Lowest Monthly % $\leq 0.3$ NTU) <i>Soil runoff</i>	N/A	TT (Limit: 95% $\leq 0.3$ NTU)	Lowest Monthly %: 99.7%	99.7% - 100%		
Turbidity (NTU/Highest Single Measurement) <i>Soil runoff</i>	N/A	TT (Limit 1 NTU)	0.39	N/A		
<b>Inorganic Contaminants</b>						
Barium (ppm) <i>Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits</i>	2	2	0.0203	0.0198 – 0.0203		
Nitrate (as Nitrogen) (ppm) <i>Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits</i>	10	10	0.39	0.36 – 0.39		
Total Nitrate & Nitrite (as Nitrogen) (ppm) <i>Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits</i>	10	10	0.39	0.36 – 0.39		
<b>Total Organic Carbon (TOC)</b>						
TOC	The percentage of TOC removal was measured each month and the system met all TOC removal requirements set by IEPA.					
<b>Unregulated Contaminants</b>						
Sulfate (ppm) <i>Erosion of naturally occurring deposits</i>	N/A	N/A	28.2	25.3 – 28.2		
Sodium (ppm) <i>Erosion of naturally occurring deposits; Used as water softener</i>	N/A	N/A	9.18	8.87 – 9.18		
<b>State Regulated Contaminants</b>						
Fluoride (ppm) <i>Water additive which promotes strong teeth</i>	4	4	0.76	0.67 – 0.76		
<b>Radioactive Contaminants</b>						
Combined Radium (226/228) (pCi/L) <i>Decay of natural and man-made deposits.</i>	0	5	0.95	0.83 – 0.95		02-04-2020
Gross Alpha excluding radon and uranium (pCi/L) <i>Decay of natural and man-made deposits.</i>	0	15	3.1	2.8 – 3.1		02-04-2020

## **Fifth Unregulated Contaminant Monitoring Rule (UCMR 5)**

As required by UCMR 5, EPA's latest monitoring cycle, the City of Chicago has completed monitoring for 25 perfluorinated & polyfluorinated alkyl substances, 4 perfluorinated alkyl acids, and lithium in its drinking water for four quarters in 2024. None of the contaminants were detected in our drinking water.

### **Units of Measurement**

ppm: Parts per million, or milligrams per liter

ppb: Parts per billion, or micrograms per liter

NTU: Nephelometric Turbidity Unit, used to measure cloudiness in drinking water

% $\leq 0.3$  NTU: Percent of samples less than or equal to 0.3 NTU



July 01, 2024

Michael Losurdo  
Leyden Township  
2501 N Mannheim Road  
Franklin Park, IL 60131

**Workorder: 2406682**

TEL:  
FAX:  
RE: IL0315880 Leyden Township UCMR 5 SE2

Dear Michael Losurdo:

Suburban Laboratories, Inc. received 5 sample(s) on 6/18/2024 for the analyses presented in the following report.

All data for the associated quality control (QC) met EPA, method, or internal laboratory specifications except where noted in the case narrative. If you are comparing these results to external QC specifications or compliance limits and have any questions, please contact us.

This final report of laboratory analysis consists of this cover letter, case narrative, analytical report, dates report, and any accompanying documentation including, but not limited to, chain of custody records, raw data, and letters of explanation or reliance. This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc.

If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

A handwritten signature in black ink that reads "Allison Phillips".

Allison Phillips  
Project Manager  
(708) 544-3260 ext 211  
aphillips@suburbanlabs.com





**Client:** Leyden Township

**Date:** July 01, 2024

**Project:** IL0315880 Leyden Township UCMR 5 SE2

**PO #:**

**WorkOrder:** 2406682

**QC Level:**

**Temperature of samples upon receipt at SLI:** C

**Chain of Custody #:**

**General Comments:**

- All results reported in wet weight unless otherwise indicated. (dry = Dry Weight)
- Sample results relate only to the analytes of interest tested and to sample as received by the laboratory.
- Environmental compliance sample results meet the requirements of 35 IAC Part 186 unless otherwise indicated.
- Waste water analysis follows the rules set forth in 40 CFR part 136 except where otherwise noted.
- Accreditation by the State of Illinois is not an endorsement or a guarantee of the validity of data generated.
- For more information about the laboratories' scope of accreditation, please contact us at (708) 544-3260 or the Agency at (217) 782-6455.
- All radiological results are reported to the 95% confidence level.

**Abbreviations:**

- Reporting Limit: The concentration at which an analyte can be routinely detected on a day to day basis, and which also meets regulatory and client needs.
- Quantitation Limit: The lowest concentration at which results can be accurately quantitated.
- J: The analyte was positively identified above our Method Detection Limit and is considered detectable and usable; however, the associated numerical value is the approximate concentration of the analyte in the sample.
- ATC: Automatic Temperature Correction. - TNTC: Too Numerous To Count
- TIC: Tentatively Identified Compound (GCMS library search identification, concentration estimated to nearest internal standard).
- SS: (Surrogate Standard): Quality control compound added to the sample by the lab.
- LA: Lab Accident - No valid data to report.
- VO: Insufficient Volume provided
- BR: Received broken
- IP: Invalid Sampling

**Method References:**

For a complete list of method references please contact us.

- E: USEPA Reference methods
- SW: USEPA, Test Methods for Evaluating Solid Waste (SW-846)
- M: Standard Methods for the Examination of Water and Wastewater
- USP: Latest version of United States Pharmacopeia

**Workorder Specific Comments:**

# PWS Analytic Search Results | SDWARS

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result (µg/L)	Status
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-05	12/18/24	200.7	lithium	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	11CI-PF3OUdS	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	4:2 FTS	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	6:2 FTS	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	8:2 FTS	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	9CI-PF3ONS	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	ADONA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	HFPO-DA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	NFDHA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFBA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFBS	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFDA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFDoA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFEESA	< MRL	PWS Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result (µg/L)	Status
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFHpA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFHpS	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFHxA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFHxS	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFMBA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFMPA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFNA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFOA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFOS	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFPeA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFPeS	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-01	12/18/24	533	PFUnA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-03	12/18/24	537.1	NEtFOSAA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-03	12/18/24	537.1	NMeFOSAA	< MRL	PWS Approved
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-03	12/18/24	537.1	PFTA	< MRL	PWS Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result (µg/L)	Status
IL0315880	00001	CC01	SE4	Suburban Laboratories, Inc.	AAL1222-03	12/18/24	537.1	PFTTrDA	< MRL	PWS Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-05	9/17/24	200.7	lithium	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	11CI-PF3OUdS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	4:2 FTS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	6:2 FTS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	8:2 FTS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	9CI-PF3ONS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	ADONA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	HFPO-DA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	NFDHA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFBA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFBS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFDA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFDaA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFEESA	< MRL	PWS Auto-Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result (µg/L)	Status
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFHpA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFHpS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFHxA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFHxS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFMBA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFMPA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFNA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFOA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFOS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFPeA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFPeS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-01	9/17/24	533	PFUnA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-03	9/17/24	537.1	NEtFOSAA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-03	9/17/24	537.1	NMeFOSAA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-03	9/17/24	537.1	PFTA	< MRL	PWS Auto-Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result (µg/L)	Status
IL0315880	00001	CC01	SE3	Suburban Laboratories, Inc.	AAI0572-03	9/17/24	537.1	PFTTrDA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-05	6/17/24	200.7	lithium	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	11CI-PF3OUdS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	4:2 FTS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	6:2 FTS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	8:2 FTS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	9CI-PF3ONS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	ADONA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	HFPO-DA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	NFDHA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFBA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFBS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFDA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFDoA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFEESA	< MRL	PWS Auto-Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result (µg/L)	Status
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFHpA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFHpS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFHxA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFHxS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFMBA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFMPA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFNA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFOA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFOS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFPeA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFPeS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-01	6/17/24	533	PFUnA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-03	6/17/24	537.1	NEtFOSAA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-03	6/17/24	537.1	NMeFOSAA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-03	6/17/24	537.1	PFTA	< MRL	PWS Auto-Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result (µg/L)	Status
IL0315880	00001	CC01	SE2	Suburban Laboratories, Inc.	AAG0385-03	6/17/24	537.1	PFTTrDA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	Suburban Laboratories, Inc.	2403B29-005A	3/13/24	200.7	lithium	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	11CI-PF3OUdS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	4:2 FTS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	6:2 FTS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	8:2 FTS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	9CI-PF3ONS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	ADONA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	HFPO-DA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	NFDHA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFBA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFBS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFDA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFDoA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFEESA	< MRL	PWS Auto-Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result (µg/L)	Status
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFHpA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFHpS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFHxA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFHxS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFMBA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFMPA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFNA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFOA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFOS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFPeA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFPeS	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	533	PFUnA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	537.1	NEtFOSAA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	537.1	NMeFOSAA	< MRL	PWS Auto-Approved
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	537.1	PFTA	< MRL	PWS Auto-Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result (µg/L)	Status
IL0315880	00001	CC01	SE1	ALS Environmental - Holland	24031147-01	3/13/24	537.1	PFTrDA	< MRL	PWS Auto- Approved



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/08/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C002**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0243-06**  
Date/Time Collected: 09/07/23 7:45  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/26/23 10:29  
Analyzed: 09/26/23 13:47

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	119		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 10:38  
Page 6 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/08/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C003**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **2310243-08**  
Date/Time Collected: 09/06/23 7:40  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/26/23 10:29  
Analyzed: 09/26/23 14:01

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	7.88		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAP (accredited by Florida DOI #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 10:38  
Page 8 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/08/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C004**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0243-03**  
Date/Time Collected: 09/06/23 12:30  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/26/23 10:29  
Analyzed: 09/26/23 13:37

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 10:38  
Page 3 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/08/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C005**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0243-01**  
Date/Time Collected: 09/06/23 7:45  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/26/23 10:29  
Analyzed: 09/26/23 13:26

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 10:38  
Page 1 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/08/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C006**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0243-04**  
Date/Time Collected: 09/06/23 14:20  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/26/23 10:29  
Analyzed: 09/26/23 13:40

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	6.08		5.00	15
Copper	399		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAP (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 10:38  
Page 4 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/08/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C007**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0243-10**  
Date/Time Collected: 09/05/23 8:12  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/26/23 10:29  
Analyzed: 09/26/23 14:08

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 10:38  
Page 10 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/14/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C008**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0533-02**  
Date/Time Collected: 09/12/23 7:25  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 10/02/23 10:30  
Analyzed: 10/02/23 15:27

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	71.3		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 14:19  
Page 2 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/14/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C009**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0533-03**  
Date/Time Collected: 09/12/23 7:30  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 10/05/23 09:21  
Analyzed: 10/05/23 10:24

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	197		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 14:19  
Page 3 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/14/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C010**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0533-04**  
Date/Time Collected: 09/12/23 7:35  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 10/02/23 10:30  
Analyzed: 10/02/23 15:38

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 14:19  
Page 4 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: LEYDEN TWSP WATER DISTRICT  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/14/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: LP1C011  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: 23I0533-08  
Date/Time Collected: 09/12/23 9:20  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 10/02/23 10:30  
Analyzed: 10/02/23 15:55

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOI #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 14:19  
Page 8 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/14/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C012**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0533-07**  
Date/Time Collected: 09/12/23 8:10  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 10/02/23 10:30  
Analyzed: 10/02/23 15:52

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	9.10		5.00	15
Copper	129		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAP (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 14:19  
Page 7 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/14/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C013**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0533-05**  
Date/Time Collected: 09/12/23 7:40  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 10/02/23 10:30  
Analyzed: 10/02/23 15:41

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOI #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 14:19  
Page 5 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/14/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C014**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0533-09**  
Date/Time Collected: 09/12/23 9:30  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 10/02/23 10:30  
Analyzed: 10/02/23 15:59

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	94.7		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 14:19  
Page 9 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/14/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C015**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0533-06**  
Date/Time Collected: 09/12/23 7:50  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 10/02/23 10:30  
Analyzed: 10/02/23 15:45

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	70.6		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 14:19  
Page 6 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/14/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LPIC016**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0533-10**  
Date/Time Collected: 09/13/23 7:30  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 10/02/23 10:30  
Analyzed: 10/02/23 16:02

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 14:19  
Page 10 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/08/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C017**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0243-07**  
Date/Time Collected: 09/07/23 0:00  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/26/23 10:29  
Analyzed: 09/26/23 13:57

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	5.79		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 10:38  
Page 7 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/08/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C018**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0243-09**  
Date/Time Collected: 09/06/23 7:30  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/26/23 10:29  
Analyzed: 09/26/23 14:04

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 10:38  
Page 9 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/08/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C019**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0243-05**  
Date/Time Collected: 09/06/23 8:30  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/26/23 10:29  
Analyzed: 09/26/23 13:43

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	5.32		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 10:38  
Page 5 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/08/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C020**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0243-02**  
Date/Time Collected: 09/07/23 7:30  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/26/23 10:29  
Analyzed: 09/26/23 13:33

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	9.34		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 10:38  
Page 2 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 08/31/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C021**  
Matrix: Drinking Water  
Sample Type:

Lab Sample ID: **23H1554-06**  
Date/Time Collected: 08/29/23 8:30  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/14/23 11:31  
Analyzed: 09/14/23 12:55

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
09/28/23 17:14  
Page 6 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 08/31/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C022**  
Matrix: Drinking Water  
Sample Type:

Lab Sample ID: **23H1554-04**  
Date/Time Collected: 08/29/23 8:35  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/14/23 11:31  
Analyzed: 09/14/23 12:48

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
09/28/23 17:14  
Page 4 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 08/31/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C023**  
Matrix: Drinking Water  
Sample Type:

Lab Sample ID: **23H1554-08**  
Date/Time Collected: 08/29/23 9:00  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/14/23 11:31  
Analyzed: 09/14/23 13:13

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOI #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
09/28/23 17:14  
Page 8 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 08/31/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C024**  
Matrix: Drinking Water  
Sample Type:

Lab Sample ID: **23H1554-05**  
Date/Time Collected: 08/29/23 8:40  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/14/23 11:31  
Analyzed: 09/14/23 12:52

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAP (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
09/28/23 17:14  
Page 5 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 08/31/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C025**  
Matrix: Drinking Water  
Sample Type:

Lab Sample ID: **23H1554-01**  
Date/Time Collected: 08/29/23 8:25  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/14/23 11:31  
Analyzed: 09/14/23 12:38

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	131		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOI #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
09/28/23 17:14  
Page 1 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 08/31/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C026**  
Matrix: Drinking Water  
Sample Type:

Lab Sample ID: **23H1554-10**  
Date/Time Collected: 08/29/23 10:30  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/14/23 11:31  
Analyzed: 09/14/23 13:20

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
09/28/23 17:14  
Page 10 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 08/31/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C027**  
Matrix: Drinking Water  
Sample Type:

Lab Sample ID: **23H1554-09**  
Date/Time Collected: 08/30/23 8:20  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/14/23 11:31  
Analyzed: 09/14/23 13:16

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
09/28/23 17:14  
Page 9 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 08/31/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C028**  
Matrix: Drinking Water  
Sample Type:

Lab Sample ID: **23H1554-07**  
Date/Time Collected: 08/29/23 8:50  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/14/23 11:31  
Analyzed: 09/14/23 13:06

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
09/28/23 17:14  
Page 7 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 08/31/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C029**  
Matrix: Drinking Water  
Sample Type:

Lab Sample ID: **23H1554-02**  
Date/Time Collected: 08/29/23 8:10  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/14/23 11:31  
Analyzed: 09/14/23 12:41

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAP (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
09/28/23 17:14  
Page 2 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 08/31/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C030**  
Matrix: Drinking Water  
Sample Type:

Lab Sample ID: **23H1554-03**  
Date/Time Collected: 08/29/23 8:15  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 09/14/23 11:31  
Analyzed: 09/14/23 12:45

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
09/28/23 17:14  
Page 3 of 11



**Illinois Environmental Protection Agency Laboratory**

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

**LABORATORY RESULTS**

Client: **LEYDEN TWSP WATER DISTRICT**  
Address: 2501 NORTH MANNHEIM RD  
City, State, Zip: FRANKLIN PARK, IL 60131  
Temperature C:

Date Received : 09/14/23  
Facility Number: 0315880  
Funding Code: PW32

Client Sample ID: **LP1C033**  
Matrix: Drinking Water  
Sample Type: Finished

Lab Sample ID: **23I0533-01**  
Date/Time Collected: 09/12/23 7:01  
Collected By:

**Metals (Drinking Water) by EPA 200 Series Methods ICP/MS**

Method: 200.8  
Units: ug/L

Prepared: 10/02/23 10:30  
Analyzed: 10/02/23 15:24

<u>Analyte</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Regulatory Level</u>
Lead	ND		5.00	15
Copper	ND		50.0	1300

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Test results meet all requirements of NELAC (accredited by Florida DOH #E37645). If you have any questions about this report, please contact the Laboratory Manager at 217.782.9780.*

**Reported:**  
10/10/23 14:19  
Page 1 of 11